

Release Notes

FLEX I/O ControlNet Adapter

Catalog Numbers 1794-ACN15, 1794-ACN15K, 1794-ACNR15,
1794-ACNR15XT Series D, Firmware Revision 10.3

Topic	Page
About This Publication	1
Before You Begin	1
Enhancements	2
Corrected Anomalies	3
Additional Information	5
Additional Resources	5

About This Publication

These release notes supplement the existing documentation supplied with your product.

Before You Begin

ATTENTION

The Series D adapter, Firmware Revision 10.3, will impact your ControlNet network and will require a new EDS file for RSLinx and RSNetworkx. RSLogix 5000 does not have to be updated as long as the adapter in the I/O configuration tree has electronic keying configured as "Compatible Keying".